SSO, Event Details Page 1 of 3



Event Search

Overflow / Bypass Event Details

Initial Report

Facility Name: Bolivar WWTF
Permit No: MO0022373

Once you enter the Event End Date & Time fields and Add Event/Save Changes, you will no longer be able t

10	
	Event Details
	Bypass = at the wastewater treatment plant; Overflow = in the collection
	Confirmation No: 2208
	*Type of Event: SSO (Overflow)
	*Wet or Dry Event? Wet
	*Event Begin Date: 04/18/2013 (MM/DD/YYYY)
	*Event Begin Time: 06:30 (HH:MM) Military Time
	**Event End Date: 04/18/2013 (MM/DD/YYYY)
	**Event End Time: 13:15 (HH:MM) Military Time
	Event Duration (hh:mm) 0d:6h:45m:
	*Initial Report Date: 04/18/2013 (MM/DD/YYYY)
	*Initial Report Time: 07:33 (HH:MM) Military Time
	Discharged To: Waterway
	*Reported By: Joe Cornell
	*Immediate Contact (417) 328 - 0271
	Ongoing?: 🔽
	*Estimated Volume at time of Initial Report (gallons): 1000.00
	Is bypass/overflow reaching Waters of the State?
	Effected Waterbody: Town Branch
	**Cause of Event: Rain
	Cause of Event Comments:

^{*} Indicates a Required Field

^{**}Indicates a Required Field for Final Report

SSO, Event Details Page 2 of 3

	plant hydraucally overloaded
Event Type:	* To select more than one choice hold down the control key
Additional Impact:	Fish Kill
	Public Beach or Public Use Area Impacted Dry Weather Release
	Drinking Water Intakes Affected Release Volume Greater Than 50,000 Gal
	Wet Event Details
*Wet Event Start Date:	04/18/2013 (MM/DD/YYYY)
**Wet Event End Date:	04/18/2013 (MM/DD/YYYY)
*Precipitation Type:	Rain
**Precipitation Amount (inches):	2.40
*Soil Conditions:	saturated
	Location Information
County	
UTM Easting:	465380.291
UTM Northing:	4163154.778
* Location Description	MH J4 090
Double click on the map to zoom in. The mouse wheel or the	he slider bar on the left side of the map may be used to zoom
	to another location. Optionally, select a County, City or Zip C
County: Polk City:	▼ Zip Code: ▼ Address:
<u> </u>	
Scale 1:2,400 Flag Icon	
Select the red indicator to activate the mark	sing tool then single click on the map to mark the location of you
- 0	The state of the s
The second secon	AND THE RESIDENCE OF THE PARTY

SSO, Event Details Page 3 of 3



5 - Day Report

**Estimated Final Total Volume (gallons): 56000.00

Did bypass reach Waters of the State?

**Response:

plant flow decreased



1-800-361-4827 / 573-751-1300

E-mail: cleanwater@dnr.mo.gov